



DPR Comments City of Corona

Project Number: PP2018-0005

Description: PRECISE PLAN

Applied: 8/31/2018

Approved:

Site Address: 1415 W SIXTH ST CORONA, CA 92882

Closed:

Expired:

Status: APPROVED

Applicant: FITNESS INTERNATIONAL, LLC

Parent Project: DPR2018-0009

3161 MICHELSON DRIVE, SUITE 600 IRVINE CA, 92612

Details: PP FOR A 37,000 SQ FT LA FITNESS ON 5 ACRES.

LIST OF COMMENTS	
DEPARTMENT	CONTACT
BUILDING	
<ol style="list-style-type: none">1. Please provide a legible copy of the performed code analysis to the building division for approval. A PDF copy can be sent to oscar.davalos@coronaca.gov2. Access, sanitary facilities, and parking shall comply with Title 24 Handicap Requirements.3. Construction activity shall not occur between the hours of 8:00 pm to 7:00 am, Monday thru Saturday and 6:00 pm to 10:00 am on Sundays and Federal Holidays.4. Roofing material shall be Class A.5. Pool area shall be enclosed with fencing in compliance with Corona Municipal Code (CMC) Sec 15.24. {THIS CONDITION WAS REMOVED BY THE PLANNING & HOUSING COMMISSION AT THE MEETING ON AUGUST 26, 2019}.6. Submit pool plans to Riverside County Health Department for approval.7. Submit five (5) complete sets of plans including the following - * Plot Plan * Foundation Plan * Floor Plan * Ceiling and roof framing plan * Electrical Plans (electrical service shall be underground per Corona Municipal Code Section 15.06), including size of main switch, number and size of service entrance conductors, circuit schedule and demand load. * Plumbing and sewer plan, isometric, including underground diagram, water piping diagram, sewer or septic tank location, fixture units, gas piping and vents, heating and air conditioning diagram. * Landscape and Irrigation plans; Submit four (4) complete sets detached from building plans. Landscape Maintenance District plans shall be submitted directly to the Public Works Department. Landscape plans shall be approved prior to the issuance of any Building Permits.8. Submit two (2) sets of structural calculations, energy conservation calculations and soils reports. Architects/Engineers stamp and wet signature is required prior to submittal of plan check.9. Upon tenant improvement plan check submittal there may be additional Building Department requirements.10. Separate permits are required for all fences, walls and paving.11. Comply with the Corona Burglary Ordinance # 15.52. Copies are available at the Building Department counter.12. All contractors must show proof of State and City licenses, and workmen's compensation insurance to the City prior to the issuance of permits.13. Business' shall not open for operation prior to posting of Certificate of Occupancy issued by the Building Department.14. All Fees Including Development Fees Must Be Paid in Full Prior to NIC or C of O Issuance15. All Fees Including City Impact Fees Must Be Paid in Full Prior to NIC or C of O Issuance16. All construction documents need to be prepared in accordance to the current applicable codes.17. The trash enclosure needs to be designed compliant with city requirements and accessible for people with disabilities including a path of travel to the enclosure.	



DPR Comments

City of Corona

FIRE	
<ol style="list-style-type: none"> 1. Place Fire Department DPR comments on plans as general notes. 2. Any revised site plan shall be submitted to the Fire Department for screen check approval prior to building plan submittal. 3. Plans shall show a minimum drive width of 28 feet for designated fire lanes. 4. Provide plans for two (2) all weather surface access ways to be approved by the Fire Prevention Manager and construct the access way(s) to accommodate 70,000 lbs GVW during all phases of construction. 5. All projects shall comply with the City of Corona Fire Department Site Construction Standard. A copy of which is available at the Fire Department counter. Projects shall have approved all weather access from two (2) directions and fire hydrants providing the required fire flow tested and accepted prior to combustible construction. 6. Provide a minimum twenty-five (25) foot inside and fifty (50) foot outside radius for access drive(s). 7. Street and drive grades shall not exceed 10% unless approved by the Fire Chief and City Engineer. 8. Any overhead obstruction such as the second story of a building, porte cochere, etc., that intrudes into the required clear width of fire vehicle access drives shall provide a minimum clear height of fifteen (15) feet unless otherwise approved by the Fire Chief. 9. A Knox Box shall be provided for the following building(s): 10. A minimum fire flow of 3000 gpm shall be provided. 11. The fire service waterline shall be looped and provided with two (2) separate points of connection. 12. Fire hydrants are to be spaced a maximum 250 feet apart. 13. Provide Class A roofing material. 14. Per 511 of the Corona Municipal Code, a public safety radio communication study is required. Consult with the Fire Department for specific requirements for this study. 15. Groves and weed abatement shall be maintained so as not to pose a fire hazard until time of development. 16. A specific address, assigned by the City of Corona, shall be provided for each building as specified by the fire department address standard which can be obtained at the fire department counter at City Hall. Address must be illuminated during all hours of darkness. 17. Fire extinguishers shall be provided prior to occupancy. Fire extinguishers shall bear a California State Fire Marshal's service tag; it shall be appropriately rated for the hazard; it shall be mounted so that the top of the extinguisher is no higher than five (5) feet above floor level; and shall be located such that the travel distance to an extinguisher does not exceed seventy-five (75) feet. 18. Obtain the following fire department permit(s): Place of Assembly 19. At no time shall fire hydrants or fire lanes be blocked by building materials, storage, equipment, and/or vehicles. 20. FR-0098-Submit separate detailed plans for review and approval of the on-site underground fireline, overhead fire sprinklers and alarm system. 	
PLANNING	Lupita Garcia
<ol style="list-style-type: none"> 1. To the fullest extent permitted by law, the applicant shall defend, indemnify and hold the City of Corona and its directors, officials, officers, employees, volunteers and agents free and harmless from any and all claims, demands, causes of action, proceedings, costs, expenses, liabilities, losses, damages or injuries of any kind, in law or equity, in any manner arising out of, pertaining to, or incident to any attack against or attempt to challenge, set aside, void or annul any approval, decision or other action of the City of Corona, whether such approval, decision or other action was by its City Council, Planning and Housing Commission or other board, director, official, officer, employee, volunteer or agent. To the extent that Government Code Section 66474.9 applies, the City will promptly notify the applicant of any claim, action or proceeding made known to the City to which Government Code Section 66474.9 applies and the City will fully cooperate in the defense. The Applicant's obligations hereunder shall include, without limitation, the payment of any and all damages, consultant and expert fees, and attorney's fees and other related costs and expenses. The City shall have the right to retain such legal counsel as the City deems necessary and appropriate. 	



DPR Comments

City of Corona

PLANNING	Lupita Garcia
	<ol style="list-style-type: none"> 2. Nothing herein shall be construed to require City to defend any attack against or attempt to challenge, set aside, void or annul any such City approval, decision or other action. If at any time Applicant chooses not to defend (or continue to defend) any attack against or attempt to challenge, set aside, void or annul any such City approval, decision or other action, the City may choose, in its sole discretion, to defend or not defend any such action. In the event that the City decides not to defend or continue the defense, Applicant shall be obligated to reimburse City for any and all costs, fees, penalties or damages associated with dismissing the action or proceeding. If at any time both the Applicant and the City choose not to defend (or continue to defend) any action noted herein, all subject City approvals, decisions or other actions shall be null and void. The Applicant shall be required to enter into any reimbursement agreement deemed necessary by the City to effectuate the terms of this condition. 3. This Precise Plan hereby allowed is conditional upon the privileges being utilized by the securing of the first permit thereof within two (2) years after the construction work is not begun within said time and carried on diligently to completion, this authorization shall become void, and any privilege or permit granted shall be deemed to have lapsed. 4. The project shall comply with all applicable requirements of the Corona Municipal Code (CMC) and ordinances and the relevant Specific Plan, if any, including the payment of all required fees. 5. The applicant or his successor in interest shall comply with the mitigation measures in the Mitigated Negative Declaration prepared for the project. 6. All landscaping, onsite and within the parkway, shall be installed per the approved plans prior to issuance of certificate of occupancy. 7. Landscape plans shall be submitted as a separate submittal to the Building Division for plan check. At time of submittal, the developer shall submit a landscape deposit in the amount of \$5,000 to the Planning Division for landscape plan check and inspection services. This is separate from the Building Division's landscape plan check submittal fee. Any money left remaining from the deposit will be reimbursed to the developer upon project completion. 8. All signage shall comply with the sign standards under Chapter 17.74 of the Corona Municipal Code for the C-3 zone. Signs shall be submitted and permitted separately over the public counter. Signage is prohibited on the north side of the building. 9. The north, east and west block walls shall be constructed of decorative block and installed prior to issuance of a certificate of occupancy. 10. The northeast corner of the property (the retention area infiltration system that abuts Pleasant View Avenue) shall be secured on all sides with a six-foot high wrought iron fence and a six-foot high wrought iron gate prior to issuance of a certificate of occupancy. 11. This project is subject to Riverside County's MSCHP fees. 12. All perimeter block walls for the project shall be treated with an anti-graffiti coating, except along the side facing the residential properties. 13. Trash enclosures shall be constructed of decorative block and shall contain a decorative trellis cover. 14. The applicant shall install security cameras in the parking lot with signage indicating the property is under surveillance. The security tapes shall be kept for 30 days for retention purposes. [ADDED AT THE PLANNING & HOUSING COMMISSION MEETING ON AUGUST 26, 2019]. 15. The applicant shall install a temporary three-foot high white vinyl fence or other fencing approved by the Community Development Department around Pad B to prevent loitering with signage indicating private property. The temporary fence shall be removed with the development of Pad B. [ADDED AT THE PLANNING & HOUSING COMMISSION MEETING ON AUGUST 26, 2019]. 16. The parking lot light poles located along the north perimeter of the project site shall be designed to prevent glare on to the adjacent residential properties to the north. The light poles will be determined by staff in conjunction with staff's review of the project's photometric analysis and light fixture design plan which the applicant shall submit to the city prior to issuance of a building permit. [ADDED AT THE PLANNING & HOUSING COMMISSION MEETING ON AUGUST 26, 2019].



DPR Comments

City of Corona

PUBLIC WORKS	Emily Stadnik
<ol style="list-style-type: none">1. The Public Works and the Departments of Water and Power, Maintenance and Parks and Landscaping Conditions of Approval for the subject application and shall be completed at no cost to any government agency. All questions regarding the intent of the conditions shall be referred to the Public Works Department Land Development Section. Should a conflict arise between City of Corona standards and design criteria and any other standards and design criteria, City of Corona standards and design criteria shall prevail.2. The developer shall comply with the State of California Subdivision Map Act and all applicable City ordinances and resolutions.3. Prior to issuance of grading permit, the applicant shall demonstrate to the satisfaction of the Public Works Director that the proposed project will not unreasonably interfere with the use of any easement holder of the property.4. All improvement and grading plans shall be drawn on twenty-four (24) inch by thirty-six (36) inch Mylar and signed by a registered civil engineer or other registered/licensed professional as required.5. The submitted site plan shall correctly show all existing easements, traveled ways, and drainage courses. Any omission or misrepresentation of these documents may require said site plan to be resubmitted for further consideration.6. In the event that off-site right-of-way or easements are required for the City of Corona master plan facilities to comply with these conditions of approval, the developer is required to secure such right-of-way or easements at no cost to the City.7. Off-site easements required to support proposed drainage outletting to Pleasant View Avenue shall be secured prior to grading permit issuance. Access for maintenance of said facilities shall also be granted.8. All existing and new utilities adjacent to and on-site shall be placed underground in accordance with City of Corona ordinances.9. Prior to issuance of a Certificate of Occupancy, the developer shall cause the engineer of record to submit project base line work for all layers in AutoCAD DXF format on Compact Disc (CD) to the Public Works Department. If the required files are unavailable, the developer shall pay a scanning fee to cover the cost of scanning the as-built plans.10. The developer shall monitor, supervise and control all construction and construction related activities to prevent them from causing a public nuisance including, but not limited to, insuring strict adherence to the following:<ol style="list-style-type: none">(a) Removal of dirt, debris or other construction material deposited on any public street no later than the end of each working day.(b) Construction operations, including building related activities and deliveries, shall be restricted to Monday through Saturday from 7:00 a.m. to 8:00 p.m., excluding holidays, and from 10:00 a.m. to 6:00 p.m. on Sundays and holidays, in accordance with City Municipal Code 15.04.060, unless otherwise extended or shortened by the Public Works Director or Building Official.(c) The construction site shall accommodate the parking of all motor vehicles used by persons working at or providing deliveries to the site. <p>Violation of any condition or restriction or prohibition set forth in these conditions shall subject the owner, applicant, developer or contractor(s) to remedies as noted in the City Municipal Code. In addition, the Public Works Director or Building Official may suspend all construction related activities for violation of any condition, restriction or prohibition set forth in these conditions until such time as it has been determined that all operations and activities are in conformance with these conditions.</p> <ol style="list-style-type: none">11. Prior to issuance of a building permit, the developer shall ensure that a homeowner's association or property owner's association is established for the purpose of maintaining all private streets, common areas and private utilities. The association documents, including any necessary Covenants, Conditions and Restrictions (CC&Rs), shall be subject to the review and approval of the Public Works Department. <p>Maintenance of all onsite BMPs for water quality purposes shall be included, as well as offsite drainage areas, outletting to Pleasant View Avenue.</p>	



DPR Comments

City of Corona

PUBLIC WORKS	Emily Stadnik
<p>12. Prior to issuance of a building permit, the developer shall finish the construction or post security guaranteeing the construction of all public improvements. Said improvements shall include, but are not limited to, the following:</p> <ul style="list-style-type: none">a) All street facilities: Sixth Street shall be core cut to determine r-values of existing AC paving. Minimum grind and overlay to 1/2 street width is required for existing streets, unless newly repaved. All missing improvements along with project frontage shall be constructed, including upgrading of any existing facilities that do not meet current City standards. This includes but is not limited to street, curb and gutter, sidewalk, parkway improvements, landscaping, irrigation, street lights, fire hydrants, etc.b) All missing drainage facilities on West Sixth Street and Pleasant View Avenue. All drainage improvements for outlet of flow along pleasant View Avenue.c) All required grading, including erosion control.d) All required sewer, water and reclaimed water facilities.e) All required landscaping and/or park facilities.f) All under grounding of overhead utilities, except for cables greater than 32k volts.g) Street improvements to include protecting FIBER OPTIC CABLE and conduit along project frontage. If conduit and cable cannot be protected, then conduit and cable must be improved to current City Standards and Specifications. <p>13. All the grading design criteria shall be per City of Corona standards, Corona Municipal Code Title 15 Chapter 15.36 and City Council Ordinance Number 2568, unless otherwise approved by the Public Works Director.</p> <p>14. Prior to approval of grading plans, the applicant shall submit two (2) copies of a soils and geologic report prepared by a Registered Engineer to the Public Works Department Land Development Section. The report shall address the soil's stability and geological conditions of the site. If applicable, the report shall also address: deep seated and surficial stability of existing natural slopes; modified natural slopes which are subject to fuel zones; manufactured slopes and stability along proposed daylight lines; minimum required setbacks from structures; locations and length of proposed bench drains, sub-drains or french drains; and any other applicable data necessary to adequately analyze the proposed development.</p> <p>15. Prior to approval of grading plans, erosion control plans and notes shall be submitted and approved by the Public Works Department Land Development Section.</p> <p>16. Prior to approval of grading plans, the applicant shall obtain a General Construction Activity Storm Water Permit from the State Water Resources Control Board in compliance with National Pollutant Discharge Elimination System (NPDES) requirements. Proof of filing a Notice of Intent (NOI) will be required by the City. The WDID # shall be displayed on the title sheet of the grading plans.</p> <p>17. Prior to approval of grading plans, the applicant shall comply with the Federal Clean Water Act and shall prepare a Storm Water Pollution Prevention Plan (SWPPP). The SWPPP shall be available at the project site for review.</p> <p>18. Prior to the issuance of a grading permit the developer shall submit recorded slope easements or written letters of permission from adjacent landowners in all areas where grading is proposed to take place outside of the project boundaries.</p> <p>19. Prior to issuance of building permits, the developer shall cause the civil engineer of record and soils engineer of record for the approved grading plans to submit pad certifications and compaction test reports for the subject lots where building permits are requested.</p> <p>20. Prior to release of grading security, the developer shall cause the civil engineer of record for the approved grading plans to submit a set of as-built grading plans with respect to Water Quality Control facilities.</p> <p>21. Prior to issuance of any grading permit, any environmental Phase I and Phase II findings and recommended actions to remove contamination resulting from previous use of the subject site shall be implemented.</p> <p>22. All City of Corona NPDES permit requirements for NPDES and Water Quality Management Plans (WQMP) shall be met per Corona Municipal Code Title 13 Chapter 13.27 and City Council Ordinance Numbers 2291 and 2828 unless otherwise approved by the Public Works Director.</p> <p>23. Prior to Planning Commission, a Preliminary WQMP shall be submitted to the Public Works Land Development Section for review and approval; applicable plan check fees shall be paid at time of submittal.</p> <p>24. Prior to the issuance of a grading permit, a Final WQMP, prepared in substantial conformance with the approved Preliminary WQMP, shall be submitted to the Public Works Land Development Section for approval. Upon its final approval, the applicant shall submit one copy on a CD-ROM in PDF format.</p>	



DPR Comments

City of Corona

PUBLIC WORKS	Emily Stadnik
<p>25. Prior to the issuance of the first Certificate of Occupancy, the applicant shall record Covenants, Conditions and Restrictions (CC \u0026R's) or enter into an acceptable maintenance agreement with the City to inform future property owners to implement the approved WQMP.</p> <p>26. Prior to issuance of the first Certificate of Occupancy, the applicant shall provide proof of notification to the future homeowners and/or occupants of all non-structural BMPs and educational and training requirements for said BMPs as directed in the approved WQMP.</p> <p>27. Prior to issuance of Certificate of Occupancy, the applicant shall ensure all structural post construction BMPs identified in the approved project specific Final WQMP are constructed and operational.</p> <p>28. All the drainage design criteria shall be per City of Corona standards and the Riverside County Flood Control and Water Conservation District standards unless otherwise approved by the Public Works Director.</p> <p>29. Prior to approval of any improvement plans, the applicant shall submit a detailed hydrology study. Said study shall include the existing, interim and the ultimate proposed hydrologic conditions including key elevations, drainage patterns and proposed locations and sizes of all existing and proposed drainage devices. The hydrology study shall present a full breakdown of all the runoff generated on- and off-site.</p> <p>30. Prior to approval of improvement plans, the improvement plans submitted by the applicant shall address the following: The project drainage design shall be designed to accept and properly convey all on- and off-site drainage flowing on or through the site. The project drainage system design shall protect downstream properties from any damage caused by alteration of drainage patterns such as concentration or diversion of flow. All residential lots shall drain toward the street. Lot drainage to the street shall be by side yard swales independent of adjacent lots or by an underground piping system. Concentrated drainage on commercial lots shall be diverted through parkway drains under sidewalks. All non-residential lots shall drain toward an approved water quality or drainage facility. Once onsite drainage has been treated it may continue into an approved public drainage facility or diverted through under-sidewalk parkway drains.</p> <p>31. Prior to building permit issuance the applicant shall provide all of the necessary documents and fees needed to annex this project into a City of Corona Community Facilities District (CFD) 2016-3 (Maintenance Services). All assessable parcels therein shall be subject to annual CFD charges (special taxes or assessments). The developer shall be responsible for all costs incurred during annexation into the CFDs.</p> <p>32. Street design criteria and cross sections shall be per City of Corona standards, approved Specific Plan design guidelines and the State of California Department of Transportation Highway Design Manual unless otherwise approved by the Public Works Director.</p> <p>33. Prior to approval of improvement plans, the improvement plans submitted by the applicant shall include the following:</p> <ul style="list-style-type: none">a) All local and/or major arterial highways' vertical and horizontal alignments shall be approved by the Director of the Public Works Department.b) All driveways shall conform to the applicable City of Corona standards and shall be shown on the street improvement plans.c) All street intersections shall be at ninety (90) degrees or as approved by the Public Works Director.d) All reverse curves shall have a minimum tangent of fifty (50) feet in length.e) Under grounding of existing and proposed utility lines.f) Street lights.g) All other public improvements shall conform to City of Corona standards. <p>34. Prior to approval of improvement plans, the improvement plans shall show all the streets to be improved to half width plus ten (10) additional feet unless otherwise approved by the Public Works Director. At the discretion of the applicant, the existing pavement maybe cored to confirm adequate section and R values during the design process and any findings shall be incorporated into the project design. Therefore improvements may include full pavement reconstruction, grind and overlay, or slurry seal. All striping shall be replaced in kind.</p> <p>35. Prior to release of public improvement security, the developer shall cause the civil engineer of record for the approved improvement plans to submit a set of as-built plans for review and approval by the Public Works Department.</p> <p>36. Prior to issuance of a building permit and/or issuance of a Certificate of Occupancy, the applicant shall pay all development fees, including but not limited to Development Impact Fees (DIF) per City Municipal Code 16.23 and Transportation Uniform Mitigation Fees (TUMF) per City Municipal Code 16.21. Said fees shall be collected at the rate in effect at the time of fee collection as specified by the current City Council fee resolutions and ordinances.</p>	



DPR Comments

City of Corona

PUBLIC WORKS	Emily Stadnik
<p>37. The applicant shall provide a separate irrigation water service for all HOA- CFD landscaped lots or easements.</p> <p>38. The landscape plans of all parkway and Landscape Maintenance District (LMD) and Community Facilities District (CFD) lots shall be prepared by a licensed Landscape Architect and shall be submitted to the City for review and approval.</p> <p>39. The developer shall install automatic irrigation to all street trees separated from adjacent residences by a fence or wall prior to the issuance of a Certificate of Occupancy.</p> <p>40. Traffic Division Prior to issuance of Certificate of Occupancy, bus shelter improvements along the frontage of the project site shall be completed to the satisfaction of the Transportation Planning Supervisor.</p> <p>41. All the potable water, reclaimed water, and sewer design criteria shall be per City of Corona Department of Water and Power standards and Riverside County Department of Health Services Standards unless otherwise approved by the Public Works and Department of Water and Power Directors.</p> <p>42. Prior to issuance of any building permits, including model home permits, a domestic water and fire flow system shall be approved by the Public Works Department and constructed by the developer, to the satisfaction of the Public Works Director and Fire Chief.</p> <p>43. Prior to improvement plans approval, the applicant shall ensure that all water meters, fire hydrants or other water appurtenances shall not be located within a drive aisle or path of travel.</p> <p>44. Prior to issuance of any building permits, the developer shall pay all water and sewer fees, including but not limited to connection fees, wastewater treatment fees, sewer capacity fees and all other appropriate water and sewer fees.</p> <p>45. Prior to building permit issuance, the applicant shall construct or guarantee the construction of all required public improvements including but not limited to, the potable water line, sewer line, reclaimed water line, potable water services, sewer laterals, reclaimed water services, double detector check assemblies and reduced pressure principle assemblies within the public right of way and-or easements.</p> <p>46. The applicant shall dedicate easements for all public water, reclaimed water, sewer and electric facilities needed to serve the project in accordance the Department of Water and Power standards. The minimum easement width shall be 20 feet for one utility and 30 feet for more than one public utility facility. All public water and sewer facilities shall be provided a minimum 20 foot wide paved access road unless otherwise approved by the General Manager. Structures and trees shall not be constructed or installed within a public utility easement.</p> <p>47. Prior to map recordation or building permit issuance, whichever comes first, the applicant shall construct or guarantee the construction of a private fire system with double detector check assemblies at all public fire services to the satisfaction of the Department of Water and Power and Fire Chief.</p> <p>48. Fire Hydrants shall be a maximum 250-300 feet apart or as directed by the Fire Department.</p> <p>49. Manhole rim elevations shall be lower than all pad elevations immediately downstream. Otherwise a back flow prevention valve will be required.</p> <p>50. Static pressures exceeding 80 psi require an individual pressure regulator.</p>	